

2812-CPR-JA5066

SILVERSEAL®
STD COMPOUND

1. Unique identification code of product-type:

SSC

EN

2. Type, Batch or serial number as required pursuant to Article 11(4):

See ETA 15/0281 : See batch number displayed on product.

3. Intended use or uses of construction product, in accordance with the applicable harmonized technical specification:

Fire Stopping and Sealing Products for Penetration Seals, See ETA 15/0281

| | | |
|---------------------------|----------------------------------|--|
| Cable Penetrations | Insulated Cables and Cable Trays | The field of application has to comply with the content of ETA 15/0281 |
| Pipe Penetrations | Insulated metal pipe | The field of application has to comply with the content of ETA 15/0281 |

4. Name, registered trade name or registered trade mark and contact address as required pursuant to article 11(5):

FSi Limited, Westminster Industrial Estate, Tamworth Road, Measham, DE12 7DS, UK

5. Authorized representative: N/A

6. System or systems of assessment and verification of performance of the construction product as set out in Annex V: AVCP - System 1

7. Harmonized standard: N/A

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:


Element issued European technical approval - ETA 15/0281 on the basis of EAD 350454-00-1104 Fire Stopping and Fire Sealing Products & issued certificate of conformity 2812-CPR-JA5066

9. Declared performance:


| Essential Characteristics | Performance/Harmonised technical specification |
|-----------------------------------|--|
| Reaction to Fire | Class F According to EN13501-1, |
| Resistance to Fire | Resistance to fire performance & field of application in accordance with EN13051-2 See ETA 15/0281 clause 3.2 - Annex C |
| Dangerous Substances | See ETA 15/0281 Clause 3.5 |
| Airbourne Sound Insulation | Tested in accordance with EN ISO 10140-2010 & EN ISO 717-1 See ETA 15/0281 Dn,ew (C;Ctr) = 52 (-4,-8) |
| Service & Durability | Z ¹ (0/+40°C) intended for use at internal conditions with high humidity (85%) in accordance with EOTA technical documents TR024, Clause 3.12 |

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

 21/01/2020
.....

L.Peach - Technical Director

 21/01/2020
.....

M.Metcalfe - Firestop Manager