

Number of the declaration of Performance: DoP018-LGS-UK

- 1 UNIQUE IDENTIFICATION CODE OF THE PRODUCT-TYPE: FLEXIC
- 2 INTENDED USE/ES: FOR FIRE COMPARTMENTATION AND/OR FIRE PROTECTION PERFORMANCE, 0843-UKTA-22/0004 AND EAD-350141-00-1106.
- 3 MANUFACTURE: FSI LIMITED, WESTMINSTER INDUSTRIAL ESTATE, TAMWORTH ROAD, MEASHAM, DE12 7DS, UK.
- 4 NOT APPLICABLE
- 5 SYSTEM/S OF AVCP: AVCP-SYSTEM 1
- 6b EUROPEAN ASSESSMENT DOCUMENTS: EAD-350141-00-1106 - September 2017  
EUROPEAN TECHNICAL ASSESSMENT: 0843-UKTA-22/0004  
TECHNICAL ASSESSMENT BODY: UL International (UK) Ltd  
NOTIFIED BODY/IESS: 0843
- 7 DECLARED PERFORMANCE:

Essential Characteristics	Performance/Harmonised technical specification
<b>Reaction to Fire</b>	Class B-s1, d0 according to EN13501-1
<b>Resistance to Fire</b>	Resistance to fire performance & field of application in accordance with EN13051-2 See 0843-UKTA-22/0004 Annex A
<b>Air Permeability</b>	Tested in accordance with EN 1026, See 0843-UKTA-22/0004 Annex B
<b>Water Permeability</b>	Tested in accordance with 0843-UKTA-22/0004 Annex C
<b>Dangerous Substances</b>	0843-UKTA-22/0004 Section 3
<b>Airborne Sound Insulation</b>	Tested in accordance with EN ISO 10140-2:2010 & EN ISO 140-3 & EN ISO 717-1 See ETA 20/1030 Clause 3.9 - Rw (C;Ctr) = 30 (G;-2) dB
<b>Service and Durability</b>	Z1 (0/+40c) intended for use at internal conditions with high humidity (85%) in accordance with EOTA technical documents TR024
<b>Movement Capability</b>	EAD 350141-00-1106, clause 2.2.13, UKTA-0843-22/0004
<b>Other</b>	Not applicable/No performance determined

in accordance with Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

FLEXI COAT®

UK

8 Appropriate Technical Documentation and/or Specific Technical Documentation: 0843-UKTA-22/0004

Link to the online copy of the declaration of performance: [www.fsilttd.com](http://www.fsilttd.com)

Signed for and on behalf of the manufacturer by:



Matthew Abbott – Technical Advisor