

Number of the declaration of Performance: DoP08-PS-UK

- 1 UNIQUE IDENTIFICATION CODE OF THE PRODUCT-TYPE: LST
- 2 INTENDED USE/ES: FOR FIRE COMPARTMENTATION AND/OR FIRE PROTECTION PERFORMANCE, 0843-UKTA-22/0014 AND EAD-350454-00-1104.
- 3 MANUFACTURE: FSI LIMITED, WESTMINSTER INDUSTRIAL ESTATE, TAMWORTH ROAD, MEASHAM, DE12 7DS, UK.
- 4 NOT APPLICABLE
- 5 SYSTEM/S OF AVCP: AVCP-SYSTEM 1
- 6b EUROPEAN ASSESSMENT DOCUMENTS: EAD-350454-00-1104 - September 2017
UK TECHNICAL ASSESSMENT: 0843-UKTA-22/0014
TECHNICAL ASSESSMENT BODY: UL International (UK) Ltd
APPROVED BODY/IESS: 0843
- 7 DECLARED PERFORMANCE:

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class F according to EN13501-1
Resistance to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See 0843-UKTA-22/0014 Annex A
Air Permeability	Tested in accordance with EN 1026, See 0843-UKTA-22/0014 Annex B
Dangerous Substances	0843-UKTA-22/0014 Section 3
Airbourne Sound Insulation	Tested in accordance with EN ISO 10140-2:2010 & EN ISO 140-3 & EN ISO 717-1 See 0843-UKTA-22/0014 Section 3 - Rw (C;Ctr) = 63 (G;-2) dB & Rw (C;Ctr) 38dB
Service and Durability	Type X intended for use at conditions exposed to weathering -20oC to +70oC in accordance with EOTA technical documents TR024
Movement Capability	EAD 350454-00-1104, clause 2.2.13, UKTA-0843-22/0014
Other	Not applicable/No performance determined

in accordance with Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

PYROPRO LST®

UK

8 Appropriate Technical Documentation and/or Specific Technical Documentation: 0843-UKTA-22/0014

Link to the online copy of the declaration of performance: www.fsilttd.com

Signed for and on behalf of the manufacturer by:



Matthew Abbott – Technical Advisor