

Number of the declaration of Performance: DoP01-UK

- 1 UNIQUE IDENTIFICATION CODE OF THE PRODUCT-TYPE: SSBT
- 2 INTENDED USE/ES: FOR FIRE COMPARTMENTATION AND/OR FIRE PROTECTION PERFORMANCE, 0843-UKTA-22/0008 AND EAD-350454-00-1104.
- 3 MANUFACTURE: FSI LIMITED, WESTMINSTER INDUSTRIAL ESTATE, TAMWORTH ROAD, MEASHAM, DE12 7DS, UK.
- 4 NOT APPLICABLE
- 5 SYSTEM/S OF AVCP: AVCP-SYSTEM 1
- 6b EUROPEAN ASSESSMENT DOCUMENTS: EAD-350454-00-1104 - September 2017  
UK TECHNICAL ASSESSMENT: 0843-UKTA-22/0008  
TECHNICAL ASSESSMENT BODY: UL International (UK) Ltd  
APPROVED BODY/IESS: 0843
- 7 DECLARED PERFORMANCE:

| Essential Characteristics | Performance/Harmonised technical specification   |
|---------------------------|--|
| Reaction to Fire          | NPD  |
| Resistance to Fire        | Resistance to fire performance & field of application in accordance with EN13051-2 See 0843-UKTA-22/0008 Annex A               |
| Air Permeability          | Tested in accordance with EN 1026, See 0843-UKTA-22/0008 Annex B   |
| Dangerous Substances      | 0843-UKTA-22/0008 Section 3  |
| Protection Against Noise  | See 0843-UKTA-22/0008 - Rw (C; Ctr) = 24(-2; -3) dB  |
| Service and Durability    | ZE (0/+40c) intended for use at internal conditions with high humidity (85%) in accordance with EOTA technical documents TR024 |
| Other                     | Not applicable/No performance determined   |

in accordance with Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

STOPSEAL BATT®

UK

8 Appropriate Technical Documentation and/or Specific Technical Documentation: 0843-UKTA-22/0008

Link to the online copy of the declaration of performance: [www.fsilttd.com](http://www.fsilttd.com)

Signed for and on behalf of the manufacturer by:



Matthew Abbott – Technical Advisor